



**THE  
NATIONAL  
BOARD**

OF BOILER AND  
PRESSURE VESSEL  
INSPECTORS

February 14, 2011

Mr. Jens Bergmann  
Leser Gmbh & Co., KG  
Wendenstrasse 133 - 135  
D-20537 Hamburg,  
GERMANY

**Subject: Capacity Certification, Valve Type: 488  
(NB Cap Cert No.: LES-M37022)**

Dear Mr. Bergmann:

We have reviewed the test results referenced below which were performed at the **Leser Laboratory** on January 11, 2011 and also enclosed please find test report numbers 30212S performed at the **National Board Testing Laboratory** on February 10, 2011, which demonstrate successful completion of testing for capacity certification of the subject valve as required by paragraph UG-136c)(3) of Section VIII of the ASME Code.

**Leser GmbH & Co., KG (Hohenwestedt, Germany)** is hereby granted capacity certification and authorization to apply the "NB" mark to the valve type listed in the scope of certification. This authorization is valid for the above location and only while the organization holds a current ASME "UV" Certificate of Authorization and is fully implementing its quality system as accepted by the National Board.

**SCOPE OF CERTIFICATION**

**Valve Type: 488**

**Organization Type: Manufacturer**

**Certified Rating Value/Sizes/Pressure Ranges:  
As Listed in NB-18**

**Certification Expiration Date: March 7, 2017**

Yours truly,

Joseph F. Ball, P.E.  
Director, Pressure Relief Department

*FILE: MF: 110214LESM37022.DOC  
REFERENCING TEST NUMBERS: 1102A071 AND 1102A081  
REVISION 1: CORRECTION OF CERT EXPIRE DATE*

1055 CRUPPER AVE.  
COLUMBUS, OHIO  
43229-1183  
U.S.A.  
614.888.8320

EXECUTIVE  
Fax 614.888.0750

TECHNICAL  
Fax 614.847.1828

PRESSURE RELIEF DEPT.  
Fax 614.848.3474

ORDER DEPARTMENT  
Fax 614.847.1147

TRAINING DEPARTMENT  
Fax 614.847.5542

EMAIL  
information@nationalboard.org

WEB SITE  
nationalboard.org