



**THE  
NATIONAL  
BOARD**

OF BOILER AND  
PRESSURE VESSEL  
INSPECTORS

November 28, 2011

Mr. Jens Bergmann  
LESER GmbH & Company KG  
Wendenstrasse 133 - 135  
20537 Hamburg,  
GERMANY

**SUBJECT: Capacity Certification, Valve Type: 526D  
(NB Cap Cert No.: LES - M37246)**

Dear Mr. Bergmann:

We have reviewed the test results referenced below which were performed at the LESER Lab on October 12, 2011 and enclosed please find a copy of test report number 31771S performed at the **National Board Testing Laboratory** on November 9, 2011 which demonstrate successful completion of testing for capacity certification of the subject valve as required by paragraph UG-136(c)(3) of Section VIII of the ASME Code(s).

**LESER GmbH & Company KG** is hereby granted capacity certification and authorization to apply the "NB" mark to the valve type listed in the scope of certification. This authorization is valid for the above location and only while the organization holds a current ASME "UV" Certificate of Authorization and is fully implementing its quality system as accepted by the National Board.

**SCOPE OF CERTIFICATION**

**Valve Type: 526D**

**Organization Type: Manufacturer**

**Certified Rating Value / Sizes / Pressure Ranges:  
As listed in NB-18**

**Certification Expiration Date: February 5, 2018**

Yours truly,

Joseph F. Ball, P.E.  
Director, Pressure Relief Department

FILE: MF: 111128LES37246.DOC

REFERENCE TEST NUMBERS: LESER 1141A331, 1141A341

REVISION 1: CONTACT NAME

1055 CRUPPER AVE.  
COLUMBUS, OHIO  
43229-1183  
U.S.A.  
614.888.8320

EXECUTIVE  
Fax 614.888.0750

TECHNICAL  
Fax 614.847.1828

PRESSURE RELIEF DEPT.  
Fax 614.848.3474

ORDER DEPARTMENT  
Fax 614.847.1147

TRAINING DEPARTMENT  
Fax 614.847.5542

EMAIL  
information@nationalboard.org

WEB SITE  
nationalboard.org