

# Certificate for Type Test of Specific Equipments (Safety Appurtenances)

Certificate No. : **TSX71000820100058**

**Manufacturer:** Leser GmbH & Co.KG  
**Address:** Itzehoer-Str.63-65,24594 Hohenwestedt Germany  
**Manufacture Range:** Pilot Operated Safety Valves  
**Type Test Report No. :** TSX7100082010058S

Characteristics which the sample valves have shown in type testing are satisfactory according to "Safety Technical Supervision Regulations for Safety Valves" and can cover the following products:

Title	Series/Type	Inlet Size mm [in]	Pressure Class MPa [Lb]	Applicable Temperature (°C)	Medium
Pilot Operated Safety Valve	810/820	< 42.6	25, 200	-85, 300	Steam, Gas, Liquid

国家特种泵阀工程技术研究中心  
 National Engineering Research Center for Specific Pump and Valve  
 型式试验专用章  
 Type Test